

ENTERGY NEW ORLEANS, INC.  
CITY OF NEW ORLEANS  
Docket No. UD-16-01

Response of: Entergy New Orleans, Inc.  
to the Second Set of Data Requests  
of Requesting Party: Alliance for Affordable  
Energy

---

---

Question No.: AAE 2-11

Part No.:

Addendum:

Question:

Please answer the following about transmission reliability:

- a. Does ENO use static line ratings or Dynamic line ratings?
  - b. If ENO uses static line ratings, has ENO analyzed how Dynamic line ratings would improve the transmission system in New Orleans?
  - c. If the answer to AAE 2-11(b) is yes, please provide this analysis.
- 
- 

Response:

- a. ENO uses both static line ratings and dynamic line ratings.
- b. No. ENO analyzes its transmission system using static line ratings. However, the Real-time Operations group may request the use of a temperature-adjusted rating for a particular transmission facility from the Operational Planning group, if real-time operational issues are observed.
- c. Not applicable. See the Company's response to part (b).