

ENTERGY NEW ORLEANS, INC.  
CITY OF NEW ORLEANS  
Docket No. UD-16-02

Response of: Entergy New Orleans, Inc.  
to the Fifth Set of Data Requests  
of Requesting Party: Alliance for Affordable  
Energy

---

Question No.: AAE 5-3

Part No.:

Addendum:

Question:

Please provide specific information about the last outage related to generation that ENO has experienced.

---

Response:

Information on the last forced outage that occurred at an ENO-owned unit, Union-1, is shown below:

unit_descr	UNION-1
event_cause_cd	6022
contrb_factor_cd	54
event_type_cd	U1
real_start_dt	5/7/17 21:00
real_end_dt	5/8/17 5:29
lost_mw	512
event_hrs	8.48
limiting_hrs	8.48
lmwh	4,343.47
gen_seq_no	838119
cause_of_event	Found tube leak prior to startup