

ENTERGY NEW ORLEANS, INC.  
CITY OF NEW ORLEANS  
Docket No. UD-16-02

Response of: Entergy New Orleans, Inc.  
to the Eighth Set of Data Requests  
of Requesting Party: Alliance for Affordable  
Energy

---

Question No.: AAE 8-12

Part No.:

Addendum:

Question:

Please discuss whether there were any generating units in the ENO service territory damaged by flooding during either Hurricane Katrina or any other flooding since Hurricane Katrina, describing

- a. the units that were damaged,
  - b. when they were damaged,
  - c. the location of the units,
  - d. the cost to repair the damaged units, and
  - e. the time required to repair or replace the damaged units.
- 
- 

Response:

- a. The generating units damaged were Michoud units 1, 2, and 3
- b. These units were damaged during Hurricane Katrina in August 2005
- c. All 3 units were located at Michoud Power Station in New Orleans.
- d. Michoud 1 was never repaired because it was not economic to do so. The cost to repair units 2 and 3 totaled \$10.7m
- e. The time required to repair units 2 and 3 and their on-line dates in 2006 were:

Michoud 2	6 Weeks	On-Line April 17
Michoud 3	16 Weeks	On-Line June 26